

**From:** Lamb, John  
**To:** ["Richard Webster"](#)  
**Cc:** [Howe, Allen](#); [Hughey, John](#); [Khanna, Meena](#); [Mensah, Tanya](#); [Tifft, Doug](#); [Hunegs, Gordon](#); [Hair, Christopher](#); [McNamara, Nancy](#); [Pelton, David](#); [Kulp, Jeffrey](#); [Patel, Amar](#); [Burnell, Scott](#); [Screnci, Diane](#); [McIntyre, David](#); [Sheehan, Neil](#); [Dacus, Eugene](#); [Weil, Jenny](#)  
**Subject:** RE: FYI - Oyster Creek Special Inspection Team Report is Issued  
**Date:** Tuesday, January 15, 2013 11:19:00 AM

---

Dear Mr. Webster:

The emergency diesel generators at Oyster Creek are not dependent on service water for cooling. They use a fan/radiator assembly for cooling, exactly like a car does. At Oyster Creek, if the service water pumps are unavailable, this has no effect on the emergency diesel generators.

Thanks.  
John

---

**From:** Richard Webster [mailto:[rwebster@publicjustice.net](mailto:rwebster@publicjustice.net)]  
**Sent:** Tuesday, January 15, 2013 11:05 AM  
**To:** Lamb, John  
**Cc:** Howe, Allen; Hughey, John; Khanna, Meena; Mensah, Tanya; Tifft, Doug; Hunegs, Gordon; Hair, Christopher; Fefferman, Carolyn (Menendez); Connolly, Hal (Menendez); Janet Tauro; David Pringle  
**Subject:** RE: FYI - Oyster Creek Special Inspection Team Report is Issued

John:

Thanks for the heads up, but this does not answer the question I previously asked. If the service water pumps go out as planned during the probable maximum flood, is there an alternative source of cooling water for the generators? If not, what would cool the spent fuel pool during the flood?

Would appreciate your response.

Thanks

Richard

Richard Webster  
Public Justice  
1825 K Street, NW Suite 200  
Washington, D.C. 20006  
Tel: (202) 630 5708  
Skype: richard.webster55  
Fax (202) 232-7203

---

**From:** Lamb, John [<mailto:John.Lamb@nrc.gov>]

**Sent:** Friday, January 11, 2013 11:48 AM

**To:** Richard Webster

**Cc:** Howe, Allen; Hughey, John; Khanna, Meena; Mensah, Tanya; Tifft, Doug; Hunegs, Gordon; Hair, Christopher

**Subject:** FYI - Oyster Creek Special Inspection Team Report is Issued

**Importance:** High

Dear Mr. Webster:

For your information, the Oyster Creek Special Inspection Team (SIT) Report was issued today. Oyster Creek Generating Station – NRC Special Inspection Report 05000219/2012009 is located in ADAMS Accession No. **ML13010A470**.

Thanks.

John